



[ULTRA WATER \(Cape Town\)](#)

41/43 Williams Way, Dunoon Milnerton

Rural, Cape Town, 7441

info@ultrawater.co.za

Office: +27 (82) 469 0436

VAT: 4120159282

"Taking Water Purification to New Heights"



Certified to
NSF/ANSI/CAN 60

Certificate of Analysis

PRODUCT: ALUMINIUM CHLOROHYDRATE

Approved for use in Portable Water up to a maximum dosage of 200mg/l

DATE : 05/02/2024

BATCH NO. : 043 AL 02/2024

PACK SIZE : 4 x 1250 kg

CHARACTERISTIC	SPECIFICATION	ACTUAL ANALYSIS
APPEARANCE	Clear to Slightly Hazy	Clear
DENSITY @ 25 °C	1.32 - 1.35	1.333
ALUMINIUM % m/m	12.0 - 12.7	12.39
CHLORIDE % m/m	7.9 - 8.5	8.11
PH (15% m/m solution)	3.5 - 4.5	4.38
TURBIDITY	Less Than 100 NTU	69.8
VISCOSITY Cp @ 25°	10 - 50	40

ANALYST: M.J. Num